

## Certificate

## UK-G59/2-1

The results of the UK-G59/2-1 tests are summarized in this certificate.

Power-One Italy S.p.a. declares that the units shipped to the UK are characterized by the following features:

- The internal specification and parameters are set to be compliant with UK-G59/2-1 engineering requirements.
- All units have identical internal parameter setting.
- These parameters cannot be changed without the usage of password protected tool.
- All units are tested before shipping according to UK-G59/2-1 engineering specification.

### SSEG DETAILS (Small-Scale Embedded Generator)

SSEG Type Reference:	PHOTO-VOLTAIC and EOLIC GRID TIED INVERTER
SSEG Model Reference:	PVI-6000-TL-OUTD PVI-6000-TL-OUTD-S PVI-6000-TL-OUTD-W PVI-5000-TL-OUTD PVI-5000-TL-OUTD-S PVI-5000-TL-OUTD-W
Manufacturer:	Power-one Italy S.p.A.
Telephone number:	+39-055-919551
Fax number:	+38-055-9195248
Address	Via S. Giorgio, 642 52028 Terranuova Bracciolini Arezzo - Italy
Maximum export capability (SSEG rating less parasitic load)	6200W (PVI-6000-TL-OUTD and derived models) 5050W (PVI-5000-TL-OUTD and derived models)
Nominal Output AC Power	6000W (PVI-6000-TL-OUTD and derived models) 5000W (PVI-5000-TL-OUTD and derived models)

### TEST HOUSE DETAILS

Name:	Power-one Italy S.p.A. - R. & D. Department
Address:	Via S. Giorgio 642, 52028 Terranuova Bracciolini
Telephone number:	+39-055-919551
Fax number:	+38-055-9195248
E-mail address	service@power-one.com

### TEST RESULTS SUMMARY

Power Quality:

- Harmonic Current Emission as per BS EN-61000-3-12
- Voltage Fluctuation and Flickers as per BS EN-61000-3-11
- DC Injection as per UK-G59/2-1
- Power Factor as per UK-G59/2-1

Protection:

- Under/Over Frequency Tests
- Under/Over Voltage Tests
- Reconnection Times
- Loss of Mains Test

Power-One Italy S.p.a.

Terranuova Bracciolini, 15 novembre 2012

Robert White  
(Director Safety & Environmental Compliance)



**UK-G59/2-1 TEST RESULTS DETAILS – TYPE VERIFICATION TEST SHEET**

**POWER QUALITY**

<b>(PVI-6000-TL-OUTD and derived models)</b>		Value of Short Circuit Power SSC = 0.198 MVA @ RSCE = 33							
Harmonic Current Emission as per BS EN-61000-3-12									
Harmonic	3rd [%A]	5rd [%A]	7rd [%A]	9rd [%A]	11rd [%A]	13rd [%A]	THD [A%]	PWHd [A%]	
Limit	21.6	10.7	7.2	3.8	3.1	2	13	22	
Test value	0.2269	0.113	0.069	0.0411	0.066	0.0624	0.3546	0.740103	

<b>(PVI-5000-TL-OUTD and derived models)</b>		Value of Short Circuit Power SSC = 0.165 MVA @ RSCE = 33							
Harmonic Current Emission as per BS EN-61000-3-12									
Harmonic	3rd [%A]	5rd [%A]	7rd [%A]	9rd [%A]	11rd [%A]	13rd [%A]	THD [A%]	PWHd [A%]	
Limit	21.6	10.7	7.2	3.8	3.1	2	13	22	
Test value	0.2535	0.1483	0.0655	0.0415	0.0526	0.0654	0.4024	0.921945	

<b>(PVI-6000-TL-OUTD and derived models)</b>					
Voltage Fluctuation and Flickers as per BS EN-61000-3-11					
Voltage Disturbance	Pst	Plt	D(t) > 3%	dc (%)	dmax (%)
Limit	1	0.65	0.5	3.3	6
Test Value	0.253	0.25	0.1	0.1	1.05

<b>(PVI-5000-TL-OUTD and derived models)</b>					
Voltage Fluctuation and Flickers as per BS EN-61000-3-11					
Voltage Disturbance	Pst	Plt	D(t) > 3%	dc (%)	dmax (%)
Limit	1	0.65	0.5	3.3	6
Test Value	0.253	0.25	0.1	0.1	1.05

<b>(PVI-6000-TL-OUTD and derived models)</b>						
UK-G59/2-1 Limit 0.25% of 30A	DC injection [mA]			Power Factor		
	75mA, tested at three power levels			0.95 lag - 0.95 lead at three voltage levels		
Test Level	10%	55%	100%	216 Vac	240 Vac	259.2 Vac
Test Value	15.3	3.6	3.8	0.992	0.996	0.998

<b>(PVI-5000-TL-OUTD and derived models)</b>						
UK-G59/2-1 Limit 0.25% of 27A	DC injection [mA]			Power Factor		
	67.5mA, tested at three power levels			0.95 lag - 0.95 lead at three voltage levels		
Test Level	10%	55%	100%	216 Vac	240 Vac	259.2 Vac
Test Value	6.1	8.2	11.1	0.991	0.995	0.998

## PROTECTION

(PVI-6000-TL-OUTD and derived models) and (PVI-5000-TL-OUTD and derived models)

UNDER FREQUENCY TEST						
Fnom=50Hz	UK-G59/2-1 Limit		Settings		Results	
Under Frequency <	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]
	47.50	20.0	47.55	20.0	47.56	20.01
Under Frequency <<	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]
	47.00	0.5	47.05	0.42	47.06	0.47

OVER FREQUENCY TEST						
Fnom=50Hz	UK-G59/2-1 Limit		Settings		Results	
Over Frequency >	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]
	51.50	90.0	51.45	90.0	51.47	90.02
Over Frequency >>	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]
	52.00	0.5	51.95	0.42	51.96	0.43

UNDER VOLTAGE TEST						
Vφ-n nom =240V	UK-G59/2-1 Limit		Settings		Results	
Under Voltage <	Voltage [V]	Time [s]	Voltage [V]	Time [s]	Voltage [V]	Time [s]
	L1-N	208.8	2.5	211.2	2.3	211.5
Under Voltage <<	Voltage [V]	Time [s]	Voltage [V]	Time [s]	Voltage [V]	Time [s]
	L1-N	192.0	0.5	194.4	0.44	194.6

OVER VOLTAGE TEST						
Vφ-n nom =240V	UK-G59/2-1 Limit		Settings		Results	
Over Voltage >	Voltage [V]	Time [s]	Voltage [V]	Time [s]	Voltage [V]	Time [s]
	L1-N	264.0	1.0	261.6	0.9	261.9
Over Voltage >>	Voltage [V]	Time [s]	Voltage [V]	Time [s]	Voltage [V]	Time [s]
	L1-N	276.0	0.5	273.6	0.44	274.0

RECONNECTION TIMES			
	Under/Over voltage	Under/Over Frequency	Loss of Main
Minimum Value Limit [s]	180	180	180
Actual setting [s]	180	180	180
Recorded value [s]	187	190	190

LOSS OF MAIN TESTS			
Method used	Rate Of Change Of Frequency and Active Power Variation		
	10%Prated	55%Prated	100%Prated
UK-G59/2-1 Limit [s]	5.0	5.0	5.0
Trip setting [s]	5.0	5.0	5.0
Trip value [s]	0.305	0.577	0.585

### SSEG Short Circuit Current Contribution Test

As Photovoltaic SSEGs are inverter connected, they are deemed to automatically comply with regulations and no further tests are required.

### SELF MONITORING – SOLID STATE SWITCHING

Not applicable because electro-mechanical relays are used

### ACCURACY

Voltage reading accuracy = +/- 1%  
 Frequency reading accuracy = +/- 0.05Hz